CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 4140-0780:101

CATEGORY: Panic Hardware

LISTEE: Monarch Hardware & Mfg., P.O. Box 548, Shepherdsville, KY 40165

Contact: Roger Vitt *(317) 715-4420 Fax (317) 715-4473

DESIGN: Models DE-18-R, DE-18-M and DE-18-C special locking arrangement. All models are

identical except for the panic device; -R indicates rim type, -M indicates mortise type and -C indicates concealed vertical rod. The system consists of a listed panic hardware device, an electromagnetic assembly, and a control box employing a piezo horn, LED's, keyswitch mechanism, and a printed circuit board. When it is activated, it is intended to monitor against unauthorized egress of persons and allow exiting within 15 seconds as permitted by code. Refer to listee's data sheet for additional detailed product description

and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction. When used with smoke

detector, the detector must be listed by CSFM.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as panic hardware for use on non-rated single swinging doors to provide a locking

means and prevent unauthorized use of the door. Authority having jurisdiction should be

consulted prior to installation.





This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 16, 2003 Listing Expires June 30, 2004

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager